

The Use of Modelica and the Functional Mockup Interface for the Building Optimization Testing Framework (BOPTTEST)

David Blum

dhblum@lbl.gov

Lawrence Berkeley National Laboratory

Berkeley, CA

Needs for advanced and improved control strategies (CS) in building and district energy systems are growing due to requirements for reducing energy use, greenhouse gas emissions, and operating costs, providing flexibility to the electrical grid, as well as ensuring performance of novel hybrid and collective system architectures. Examples of such CS are advanced rule-based control, Model Predictive Control (MPC) [Drg20], and Reinforcement Learning [Wan20]. However, while these and other CS show promise, two challenges slow their widespread adoption:

1. The performance of each CS is typically demonstrated on individualized case studies and quantified using different performance indicators, making it difficult to properly benchmark and compare their performance, identify the most promising approaches, and identify needed further development.
2. Demonstrations in real buildings and district energy systems pose large operational risks and difficult environments for controlled experiments. The building simulation (BS) community can address these challenges by providing suites of publicly available, high-fidelity simulation models, called emulators, to be used for benchmarking CS.

Furthermore, providing a comprehensive framework to deploy, interact with, and generate key performance indicators (KPI) from these emulators would ensure their benchmarking capability and make them readily available to related control and data science fields outside of the BS community. There exists precedent for such an approach in the optimization fields (e.g. Decision Tree for Optimization Software [Mit22]) and data science (e.g. OpenAI Gym [Ope22]). Work is underway on the envisioned framework and emulators, called the Building Optimization Testing Framework (BOPTTEST). It has been developed within the IBPSA Project 1 Work Package 1.2 [Wet19], with primary software development occurring open source at <https://github.com/ibpsa/project1-boptest>. The framework is described in [Blu21] and has been used so far in [Arr20, Arr22, Bun21, Hua18, Wal20, Yan20]. Additional development is making BOPTTEST available as a web-service, providing an online dashboard to share and sort results, and creating an OpenAI Gym interface [Arr21]. The Role of Modelica and Functional Mockup Interface Key to the implementation of BOPTTEST is the development of high-fidelity building emulators that can represent HVAC system dynamics in a way that can realistically emulate how building controls are implemented and perform in practice. For the implementation of these models, we use Modelica libraries developed under IBPSA Project 1 for the purposes of building and urban energy system simulation. For packaging these models in a shareable format and simulating within the BOPTTEST run-time environment, we use the Functional Mockup Interface (FMI). This presentation will present the motivation, design, and example usage of BOPTTEST, emphasizing how Modelica and FMI enable its core capabilities.

REFERENCES

- [Arr20] Arroyo, J., Spiessens, F., and Helsen, L. (2020). Identification of Multi-zone Grey-box Building Models for Use in Model Predictive Control. *Journal of Building Performance Simulation* 13 (4):472–486.
- [Arr21] Arroyo, J., C. Manna, F. Spiessens, and L. Helsen (2021). “An OpenAI-Gym environment for the Building Optimization Testing (BOPTTEST) framework.” In Proceedings of the 17th IBPSA Conference, Bruges, Belgium, Sep. 1-3.
- [Arr22] Arroyo, J., Manna, C., Spiessens, F., and Helsen, L. (2022). Reinforced model predictive control (RL-MPC) for building energy management. *Applied Energy* 309: 118346.
- [Blu21] Blum, D., Arroyo, J., Huang, S., Drgona, J., Jorissen, F., Walnum, H. T., Chen, Y., Benne, K., Vrabie, D., Wetter, M., and Helsen, L. (2021). Building Optimization Testing Framework (BOPTTEST) for Simulation-Based Benchmarking of Control Strategies in Buildings. *Journal of Building Performance Simulation*, 14(5), 586-610.
- [Bun21] Bünning, F., Pfister, C., Aboudonia, A., Heer, P., and Lygeros, J. (2021). Comparing Machine Learning Based Methods to Standard Regression Methods for MPC on a Virtual Testbed. In Proceedings of the 17th IBPSA Conference, Sep 1 - 3. Bruges, Belgium.
- [Drg20] Drgoña, J., Arroyo, J., Cupeiro Figueroa, I., Blum, D., Arendt, K., Kim, D., Ollé, E. P., Oravec, J., Wetter, M., Vrabie, D. L., and Helsen, L. (2020). All you need to know about model predictive control for buildings. *Annual Reviews in Control*, 50, 190–232.
- [Hua18] Huang, S., Chen, Y., Ehrlich, P. W., and Vrabie, D. L. (2018). A Control-Oriented Building Envelope and HVAC System Simulation Model for a Typical Large Office Building. In Proceedings of 2018 Building Performance Modeling Conference and SimBuild co-organized by ASHRAE and IBPSA-USA, Sep 26 - 28. Chicago, IL.
- [Ope22] OpenAI (2022). Gym. Available online: <https://gym.openai.com>.
- [Mit22] Mittelmann, H. D. (2022). Decision Tree for Optimization Software. Available online: <http://plato.asu.edu/guide.html>.
- [Wal20] Walnum, H. T., Sartori, I., and Bagle, M. (2020). Model Predictive Control of District Heating Substations for Flexible Heating of Buildings. In SINTEF Proceedings no 5, ser. BuildSim-Nordic 2020, Oct 13-14. Oslo, Norway: International Conference Organised by IBPSA-Nordic, 123-130.
- [Wan20] Wang, Z., and Hong, T. (2020). Reinforcement Learning for Building Controls: The Opportunities and Challenges. *Applied Energy* 269:115036.
- [Wet19] Wetter, M., C. van Treeck, L. Helsen, A. Maccarini, D. Saelens, D. Robinson, and G. Schweiger (2019). “IBPSA project 1: BIM/GIS and modelica framework for building and community energy system design and operation – ongoing developments, lessons learned and challenges,” Proc. of the Sustainable Built Environment Conference, vol. 323, p. 012114. <https://doi.org/10.1088/1755-1315/323/1/012114>.
- [Yan20] Yang, T., Filonenko, K., Arendt, K., and Veje, C. (2020) Implementation and Performance Analysis of a Multi-Energy Building Emulator. In 2020 6th IEEE International Energy Conference (ENERGYCon), Sep 28 - Oct 1. Gammarth, Tunisia, 451-456.